

AWWA Free Water Audit Software

Water Balance



Water Audit Report for: **Town of Fort Erie**

Audit Year: **2024**

Jan 01 2024 - Dec 31 2024

Data Validity Tier: **Tier IV (71-90)**

FWAS v6.0

American Water Works Association.
Copyright © 2020, All Rights Reserved.

Volume from Own Sources (VOS) (corrected for known errors)	System Input Volume	Water Exported (WE) (corrected for known errors)	Billed Water Exported				Revenue Water (Exported)
		0.000					0.000
0.000	4,565.820	Water Supplied 4,565.820	Authorized Consumption 3,018.523	Billed Authorized Consumption 2,906.771	Billed Metered Consumption (BMAC) (water exported is removed) 2,882.715	Revenue Water	
					Billed Unmetered Consumption (BUAC) 24.056	2,906.771	
				Unbilled Authorized Consumption 111.752	Unbilled Metered Consumption (UMAC) 37.178	Non-Revenue Water (NRW)	
					Unbilled Unmetered Consumption (UUAC) 74.574		
			Water Losses 1,547.297	Apparent Losses 77.167	Systematic Data Handling Errors (SDHE) 7.267	1,659.049	
					Customer Metering Inaccuracies (CMI) 62.633		
					Unauthorized Consumption (UC) 7.267		
				Real Losses 1,470.130	Leakage on Transmission and/or Distribution Mains Not broken down		
					Leakage and Overflows at Utility's Storage Tanks Not broken down		
					Leakage on Service Connections Not broken down		
Water Imported (WI) (corrected for known errors)							
4,565.820							